

number 305181/01 Replaces -  
Date of issue 15-02-2024 Issued first 15-02-2024  
Report number P000320518

## Declaration regarding the efficiency of a shower heat recovery unit

### DECLARATION OF KIWA

This declaration is based on a single examination by Kiwa on a product supplied by

### Zypho, SA

This declaration does not pass a judgment on other products supplied by the manufacturer. The products mentioned below were tested according the procedure according annex U of the NTA 8800:2023.

### Zypho Slim 50 DW

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance ( $\Delta P$ ) (bar)
2	5.8	47	52.6	0.20
3	9.2	73	51.2	0.47
4, 5, 6	12.5	100	46.5	0.81

Allard Slomp  
Product Manager



Kiwa Nederland B.V.

Kiwa Nederland B.V.  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands  
Tel. 088 998 33 55  
[info@kiwa.com](mailto:info@kiwa.com)  
[www.kiwaenergy.com](http://www.kiwaenergy.com)

Zypho SA  
Tower Plaza I,  
Via Eng. Edgar Cardoso 23, 5º H  
4400-676 Vila Nova de Gaia,  
PORTUGAL  
+351 210 991 351  
[b2b@zypho.pt](mailto:b2b@zypho.pt)  
[www.zypho.pt](http://www.zypho.pt)

